


B	T802 ut, 030708, VRa/AJK	Rev.	Description Date/Sign.
A	120>200 C 950301BSwl	Rev.	Description Date/Sign.

ORDERING EXAMPLE : MN3192 S 235 U 15
 Mechanical design _____
 Single element(Letter no.1) _____
 Length of temp.sensor (L),in mm _____
 Element type Pt100(Letter no.2) _____
 Cable length (CL) in dm _____

LETTER NO.1	EXPLANATION
S	Single element, 2-wire
T	3-wire connection

LETTER NO.2	ELEMENT TYPE	RANGE
M	Pt1000ohm/0°C	-50 to 200°C
U	Pt100 ohm/0°C	-50 to 200°C



Date 1990-01-23	Dsgn/Dwn AK/SR	Trac	Scale/Format 1:1
Checked ELS	Spec Ctrf. AJK	Approved	

Kongsberg Maritime AS
Automation
Trondheim

Temperature sensor type MN3192-----

DIMENSIONAL SKETCH

Repl. for	Repl. by	Next sheet
Dwg no. MN-3192	Sh.no.	Rev. Lang. B